

Test Report No: SYD -74116273

Slip Resistance Measurement of Existing Pedestrian Surfaces: AS4586:2013 Appendix A

Client: OWS International Building Services Pty Ltd

Test Date: 07/12/2022

Temperature: 23 deg c.

Conducted To: AS4586:2013 Appendix A

Conducted by: Jose Rodriguez

Test Method: Wet Pendulum

Test Device: Wessex S/N - SK2015

Surface: Bluestone outdoor

Calibration Date: 16/12/2020

Rubber Slider Used: Slider 96 (4 S Rubber)

Slider Preparation: Abrasive Paper, Grade P400 & 3µm lapping film

Test Location: 1/17 Pavesi Street Smithfield NSW 2164

Surface Preparation: Cleaned with water and pH neutral detergent

Surface Application: N/A

Tested Area	Condition:	As found	Direction of Test:	Direction of Traffic
	Gradient (°):	less than 1.5	Test Type:	Loose
	Temp. Correction:	N/A		

Specimen Number	Location	Mean SRV
1	Loose Tile	69
2	Loose Tile	67
3	Loose Tile	66
4	Loose Tile	64
5	Loose Tile	64

Mean SRV	66
Slope Correction	
Slip Resistance Value	66
Classification	P5

Interpretation of Results			
Test Type	Class.	Slip Resistance Value	
		Slider 96	Slider 55
Wet	P5	>54	>44
	P4	45-54	40-44
	P3	35-44	35-39
	P2	25-34	20-34
	P1	12-24	<20
	P0	<12	
Dry	D1	≥0.40	
	D0	<0.40	

The AS 4586 standard provides a guide & recommendation for use, we recommend that this report be read in conjunction with AS 4586 & Handbook HB198: 2014. Refer to Table 3B of HB 198 for requirements of sloped surfaces & ramps. The results in this test do not account for any future wear, contamination or maintenance of this surface. Slipstop Australia Pty Ltd or our agents, licencees or employees accept no responsibility for any actions whatsoever which may arise as a result of this test report, all information within this report is copyright & is protected by copyright law.

Approved Signatory: Steve Stojcevski



 S-010720 V.1
1st July 2020